

SECTION 13132

ALUMINUM GEODESIC DOME COVERS

(STRUCTURAL ALUMINUM WALL SUPPORTED WITH CLADDING)

Revision 1.0 — April 2026

PROJECT TEMPLATE: This document is provided as a specification template. Contact RPS Engineering at 847-931-1950 to work with our team on completing project-specific load requirements and specifications for your facility.

PART 1 — GENERAL

1.1 SECTION INCLUDES

- A. Aluminum Geodesic Dome Covers, sidewall system, mechanical/ventilation system and controls accessories, and anchorage hardware.

1.2 REFERENCES

- A. ASTM C-509 — Specification for Elastomeric Cellular Preformed Gasket and Sealing Material
- B. ASTM F593 — Specification for Stainless Steel Bolts, Hex Cap Screws and Studs
- C. ASTM F594 — Specification for Stainless Steel Nuts
- D. ASCE 7-22 — American Society of Civil Engineers Minimum Design Loads for Buildings and Other Structures
- E. Aluminum Association Specifications for Aluminum Structures
- F. International Building Code (IBC) 2021

1.3 DESIGN REQUIREMENTS

- A. Dome structure shall be a fully triangular space truss complete with non-corrugated closure panels for both sidewalls and dome. Panels for the dome shall be non-corrugated.
- B. The dome cover structure shall be designed for the loads specified herein, within stress limitations of the Aluminum Association Specifications for Aluminum Structures.
 - 1. Dead Load — weight of the structure and all material attached to and supported by the structure.
 - 2. Snow Load
 - a. Ground Snow Load = _____
 - b. Exposure Factor = _____
 - c. Importance Factor = _____
 - d. Thermal Factor = _____
 - e. Slope Factor = _____
 - 3. Wind Load
 - a. Exposure Category = _____
 - b. Basic Wind Speed = _____

- c. Importance Factor = _____
 - d. Topographic Factor = _____
4. Earthquake Load
- a. Importance Factor = _____
 - b. Site Classification = _____
 - c. Seismic Design Category = _____
 - d. 0.2s Spectral Response Acceleration (S_s) = _____
 - e. 1.0s Spectral Response Acceleration (S₁) = _____
- C. In addition to the above loadings, the dome panels shall be designed for two concentrated loads of 250 pounds each, applied simultaneously on two separate one square foot areas of the panel and the ground snow load distributed over the entire panel area.
- D. The design and details shall provide for Thermal Expansion and Contraction over an ambient air temperature range of -30°F to 120°F.
- E. Horizontal forces shall be contained by an integral tension ring, and no horizontal force shall be imposed on the supporting structure under temperature variations.
- F. Design shall include provisions to allow for radial displacements under live load.
- G. The dome cover shall be clear span and self-supporting from its periphery.
- H. Materials shall be suitable for continuous exposure to hydrogen sulfide (H₂S) gas and other corrosive byproducts of wastewater treatment environments.
- I. The following loading combinations shall be considered:
- 1. Dead Load plus Uniform Snow Load on entire dome.
 - 2. Dead Load plus Unbalanced Snow Load.
 - 3. Dead Load plus Wind Load.
 - 4. Dead Load plus Uniform Snow Load plus Wind Load.
 - 5. Dead Load plus Unbalanced Snow Load plus Wind Load.
- J. Dome shall include a sidewall system that extends 8'-0" above the top of the tank wall. Sidewalls shall include a 3'-0" x 7'-0" door as specified herein and 24-inch square access hatches in every other panel around the periphery. Cladding panels to be .040" 3003 H-14 aluminum, 1½" x 7.2" RPS Rib with 36" coverage. Hatches shall be positioned to provide continuous clear access to the launder area.
- K. Field measurement and coordination with the mechanism specified shall be performed to ensure that the dome does not interfere with the mechanism, walkway, guards, etc. and that the dome is properly flashed and watertight at walkway beams bearing on the existing concrete wall.

1.4 SUBMITTALS

- A. Submit complete Shop Drawings including fabrication and erection drawings, stamped by a Professional Structural Engineer registered in the State where dome(s) will be erected.
- 1. Include complete dimensioned details, sizes, thicknesses, gauges, material, finishes, all connection details, anchorage details to concrete Clarifiers and other information as necessary to completely describe the structure size, configuration and construction.
 - a. Dome Structure — Provide a detailed drawing of the dome structure and a completed table of structural member and connection information, indicating piece marks, number of bolts and diameter at each connection and member flange widths and thicknesses. Piece marks shall correspond to detailed drawing.

- j. Push to test motor over temperature alarm light (red) on front of control panel with nameplate.
- 5. If forced ventilation system is not required, dome manufacturer to provide properly sized gravity vent.

1.5 QUALITY ASSURANCE

- A. The dome manufacturer shall exhibit satisfactory performance on projects of similar magnitude under similar or equal service conditions for a period not less than five (5) years. Submit past job list with Owner contact information.

1.6 DELIVERY, STORAGE AND HANDLING

- A. The contractor shall be responsible for offloading and storing the aluminum dome cover panels and materials. The dome materials shall be stored off the ground on a level surface to prevent warping.

1.7 WARRANTY

- A. The Contractor shall obtain a warranty from the manufacturer in the name of the Owner. Submit the fabricated aluminum dome Manufacturer's Warranty to the Engineer for review.
- B. The Manufacturer's Warranty shall guarantee the fabricated dome materials, workmanship and hardware to be free of defects for a period of three (3) years from the date of substantial completion as defined in the General Conditions.

1.8 FIELD MEASUREMENTS

- A. Field measurements shall be taken at the site prior to fabrication in order to verify indicated dimensions and to ensure proper fitting of all items.

PART 2 — PRODUCTS

2.1 MANUFACTURER

- A. RPS Engineering
 - 1. 1300 Crispin Drive, Elgin, IL 60123
 - 2. Phone: 847-931-1950 | Fax: 847-931-4274
 - 3. www.rpsengineering.com
 - 4. Woman-Owned Business

2.2 MATERIALS

- A. Structural Shapes and Plates — Aluminum Alloy 6061-T6 or equal.
- B. Panels — 16-gauge (minimum) Aluminum Alloy 3003-H16 or equal. Plates and sheets shall be mill finished.

- C. Tension Ring — Aluminum Alloy 6061-T6 or equal.
- D. Natural Lighting Panels % of tank surface area (minimum) clear acrylic.
- E. Fasteners — Type 316 stainless steel, aluminum alloy 2024-T4 or anodized aluminum alloy 7075-T73 including flat washers, lock washers and nuts.
- F. Sealant — Dow 790 Silicone, FS TT-S-001543A and FS TT-S-00230C, or equal.
- G. Gaskets — Neoprene Gasket conforming with ASTM C-509 or Silicone Gaskets.
- H. Support Bearing Pads — Teflon faced neoprene on stainless steel.
- I. Epoxy Anchors, Bolts, Flat Washers, Nuts and Lock Washers — Type 316 Stainless Steel.
- J. Hardware — Assembly hardware and rail nut plates shall be Type 316 stainless steel.
- K. Sidewalls — Minimum height of 8'-0" above the tank wall. Cladding panels: .040" 3003 H-14 aluminum, 1½" x 7.2" RPS Rib with 36" coverage. Access door: 3'-0" x 7'-0" aluminum, reinforced door and frame withhold-open device.
- L. Aluminum Relief Vents and Bird Screen — Aluminum Alloy 6061-T6 or 3003-H16.
- M. Aluminum Hatches — Furnished with lockable hasp and capable of being secured when opened. Minimum clear opening 24" x 24". Aluminum Alloy 6061-T6 or 3003-H16.
- N. Entry Door — Lockset, hinges, and door hold-open device provided under Division 08.
- O. Provide an aluminum drip edge to channel rainwater off the dome and top of concrete walls.
- P. Provide grounding lugs and mechanical lugs mounted to three (3) points of lower dome for grounding at each dome location. Coordinate final locations with Division 26 – Electrical.
- Q. All materials shall be resistant to hydrogen sulfide (H₂S) and corrosive gases typical of wastewater treatment environments.

PART 3 — EXECUTION

3.1 FABRICATION AND ERECTION

- A. All work shall be executed by workmen skilled and experienced in the fabrication and erection of aluminum domes.
- B. The dome shall be erected plumb and level and in proper alignment by the dome fabricator.
- C. A minimum of four (4) fasteners per flange shall be used to connect structural members to gusset plates.
- D. No welding or thermal cutting of aluminum structural members supports or connections shall be allowed.
- E. All raw edges of the aluminum panels shall be covered, sealed and firmly clamped in an interlocking manner to prevent slipping or disengagement under all load and temperature changes, and shall be watertight.
- F. All sealant joints shall be tooled slightly concave after sealant is installed.
- G. The domes shall be grounded in accordance with manufacturer's requirements.
- H. Install hardware as provided under Division 08.
- I. General Contractor shall coordinate configuration of door and flashing with interior walkway platform and guard provided under the applicable specification section.

3.2 CLEANUP

- A. Dome Contractor shall be responsible for removal of all equipment and materials related to the dome construction from the site.

END OF SECTION 13132